

TABLE of CONTENTS

SS Specification

Section	Description	Page No.
1.0	Introduction	1
2.0	Applicable Standards, Codes and Regulations	1
3.0	Environmental Conditions	1
4.0	System Description	1
5.0	System Operation	2
	5.1 Normal	2
	5.2 Low DC Disconnect	2
	5.3 Bypass	2
	5.4 Load Transfer	2
	5.5 Manual Bypass	2
	5.6 System Start-Up	3
	5.7 System Shut-Down	3
6.0	Static Inverter	3
	6.1 General	3
	6.2 Output Voltage	3
	6.3 Input Voltage	4
	6.4 Voltage Regulation	4
	6.5 Frequency Regulation	4
	6.6 Frequency Control	4
	6.7 Load Power Factor	4
	6.8 Harmonic Distortion	4
	6.9 Crest Factor	4
	6.10 Slew Rate	5
	6.11 AC Transient Response	5
	6.12 AC Transient Recovery	5
	6.13 Overload Capability	5
	6.14 DC Transient	5
7.0	Static Transfer Switch	5
	7.1 General	5
	7.2 Operation	5
	7.3 Transfer Time	6
	7.4 Transfer Point	6
	7.5 Auto-Retransfer Defeat	6
	7.6 Overload Rating	6

8.0	Manual Bypass Switch	7
	8.1 General	7
	8.2 Mounting	7
	8.3 Configuration	7
	8.4 Overload Rating	7
9.0	Accessories	7
	9.1 Controls	7
	9.2 Meters	8
	9.3 Indicating Lights and Alarms	8
	9.4 Optional Indicating Lights and Alarms	9
	9.5 Overload Protection	11
10.0	General Requirements	12
	10.1 System Efficiency	12
	10.2 Audible Noise	12
	10.3 Cooling	12
	10.4 Wiring	12
	10.5 EMI Suppression	13
	10.6 Transformers	13
	10.7 Nameplate Markings	13
11.0	Mechanical Specifications	13
	11.1 Enclosure	13
	11.2 Ventilation	14
	11.3 Cable Entry	14
	11.4 Power Connections	14
	11.5 Parts Placement	14
	11.6 Wire Support	14
	11.7 Wire Marking	15
	11.8 Component Marking	15
	11.9 Personnel Safety	15
	11.10 Painted Surfaces	15
12.0	Shop Testing	15
13.0	Documentation	15
	13.1 Outline Drawings	15
	13.2 Schematic Drawings	16
14.0	Preparation for Shipment	16

1.0 INTRODUCTION

This specification describes a continuous duty, solid-state, on-line inverter. This means that under normal conditions, power is provided to the load through the inverter. Incoming DC power from a Rectifier/Battery Charger or station battery is converted to clean, conditioned AC power. The inverter shall operate in conjunction with the existing building/plant electrical systems to provide high quality power to the critical load. The Inverter system shall consist of an integrated Inverter bridge, Constant Voltage Transformer (CVT), Static Transfer Switch, and Manual Maintenance Bypass Switch.

2.0 APPLICABLE STANDARDS, CODES AND REGULATIONS

Unless noted otherwise, the design, fabrication, testing, and performance of the system shall be in accordance with the latest revisions of the following industry/agency standards and codes, where applicable:

National Electrical Manufacturers Association (NEMA)
American National Standards Institute (ANSI)
National Electric Code (ANSI/NFPA 70)
Institute of Electrical and Electronic Engineers (IEEE)
International Electrotechnical Commission (IEC)

3.0 ENVIRONMENTAL CONDITIONS

3.1 Operating Temperature

The system shall operate at rated output without any adverse affects in an ambient temperature of 0° C to 40° C (32° F to 104° F), except batteries.

3.2 Relative Humidity

The system shall operate at a relative humidity of 5% to 95% non-condensing for a temperature range of 10° C to 40° C.

3.3 Operating Altitude

The system shall operate at any altitude from sea level up to 2500m Meters (8,200ft) above sea level without de-rating.

4.0 SYSTEM DESCRIPTION

Each inverter system shall consist of the following major components:

Static Inverter (Single-Phase Output)
Static Transfer Switch (Zero- break)
Manual Bypass Switch (Electro-Mechanical; Make Before Break)
Battery Bank

5.0 SYSTEM OPERATION

5.1 Normal

The critical load is continuously supplied by the inverter, with isolated, regulated AC voltage. The inverter output shall be in phase with the bypass source.

If the bypass source deviates more than +/-0.5% of (50 or 60 HZ) the inverter output shall run on its own internal oscillator until the reference source returns to within acceptable limits.

5.2 Low DC Disconnect

When the battery voltage reaches 105 VDC (210 VDC on nominal 250 VDC systems) for 5 seconds, the system shall automatically transfer the load to bypass and disconnect the battery via a shunt trip in the breaker to prevent damage to the batteries.

5.3 Bypass

During an overload or load fault, at the inverter output, the static switch shall automatically transfer the load to commercial power (transfer point factory set @ 120% of rated load) without interruption.

On clearing an inverter malfunction, fault or overload condition, the static transfer switch shall automatically transfer the U.P.S. load from the bypass to the inverter output. The transfer from both directions shall be without interruption (zero-break). A static switch transfer can only be accomplished when the inverter output is in sync with the bypass source. (except during inverter failure)

Transfer to the bypass may also be accomplished manually by the Bypass to Load push button without interruption. This shall lock out the auto retransfer function.

Upon the deterioration or failure of the inverter bridge output load to bypass without any interruption.

5.4 Load Transfer

Pressing the Bypass to Load push button while the inverter is supplying the load, the static switch shall transfer the load to the bypass source if the bypass source is available and it is in sync with the inverter. The operation of the Inverter to Load push button is the same as the Bypass to Load push button except it transfers the load to the inverter.

5.5 Manual Bypass

During maintenance, the system may be bypassed without interruption to the load for ease of inspection.

5.6 System Start-Up

- Press the pre-charge button (provided on units 20 kVA and larger) until the pre-charge LED is lit.
- Close the Bypass Source AC Circuit Breaker.

As soon as the inverter output is synchronized with the bypass source, the “In-Sync” LED will light. (Note: If the Auto-Retransfer switch is in the “ON” position, the static switch will automatically transfer the load onto the inverter).

- Verify that the static switch is in the “Bypass To Load” position, and transfer the manual bypass switch to the “NORMAL” position.
- Press ‘Inverter To Load’ pushbutton.

The inverter is now supplying clean, uninterrupted power to the load.

5.7 System Shut-Down

- Press ‘Bypass To Load’ pushbutton.
- Transfer manual bypass switch to the “Bypass To Load” position.
- Open Bypass Source AC Circuit Breaker

The load is now being powered by the alternate (or bypass) AC source via the Manual Switch.

6.0 STATIC INVERTER

6.1 General

The static inverter shall be a ferroresonant type, generating single phase AC power. The inverter shall be capable of providing continuous and uninterruptible output power while operating from any DC source within the operating input range.

6.2 Output Voltage

The inverter's output circuit shall be magnetically isolated from the input circuit and be supplied with a convenient means of grounding or ungrounding the inverter's output

The inverter's output voltage shall be maintained for at least 1/2 cycle during an input bridge failure to insure a zero-break static transfer to the bypass source. The inverter's output voltages shall be supplied in standard 50 or 60 Hz values

6.3 Input Voltage

The maximum DC input voltage shall range from 105-147 VDC (210-294 VDC for nominal 250 VDC systems) while maintaining the specified output voltage.

6.4 Voltage Regulation

The inverter steady state output voltage regulation shall not change more than +/-2% under any of the following conditions:

1. 0 to 100% and 100% to 0 load change.
2. Minimum to maximum DC bus voltage.

6.5 Frequency Regulation

The free-running, steady state output frequency of the inverter shall not deviate more than 0.5 Hz due to the following conditions,

1. 0% to 100% load
2. Minimum to maximum ambient temperature
3. Minimum to maximum DC bus voltage

6.6 Frequency Control

The output frequency of the inverter shall be controlled by an oscillator, which can be operated as a free-running unit or as a slave for synchronized operation with a separate AC source. The inverter shall track the AC reference source provided it is 50 or 60 ($\pm 0.5\%$) HZ. Upon failure or excessive frequency deviation of the reference, the oscillator shall automatically revert to its free-running mode.

6.7 Load Power Factor

The inverter shall be capable of handling linear loads of 0.8 pf -1.0 pf while maintaining a +/-2% regulation and non-linear loads (switch-mode power supplies) with a power factor range of 0.7 to 1.0.

6.8 Harmonic Distortion

The inverter shall limit the total harmonic distortion of the output voltage to less than 5% RMS total with a 100% linear load or less than 7.5% THD with a 100% switch-mode type load.

6.9 Crest Factor

The inverter shall be capable of supplying non-linear loads exhibiting a crest factor of up to 3.0 at full load without additional filtering or increasing the size of the system.

6.10 Slew Rate

The inverter frequency rate of change shall not exceed 1 Hz/second when synchronizing to the bypass reference.

6.11 AC Transient Response

The inverter voltage transient response shall not exceed + 8% to - 10% due to a 100%-50% or 50%-100% step load change. During a 100% step load the maximum deviation shall be 23% for the first half cycle.

6.12 AC Transient Recovery

The output voltage, following the step load changes listed above, shall return to within $\pm 2\%$ of the steady state output voltage within 50 milliseconds.

6.13 Overload Capability

The inverter shall be capable of supplying loads up to 120% of the rated load for 10 minutes without transfer to the bypass. The inverter shall current limit at approximately 175% and supply up to 500% rated current for approximately one cycle.

6.14 DC Input Transient

The DC input shall include an input filter to suppress externally generated DC transients and to control inverter switching transients at the battery. Filtering shall be designed to suppress a transient of 4000 volts, with a 10 micro second duration, occurring at the inverters DC input terminals.

7.0 STATIC TRANSFER SWITCH

7.1 General

The static switch shall be a naturally commutated, high speed transfer device provided as an integral part of the U.P.S. The control of the unit shall provide an automatic or manual uninterrupted transfer of the load to the bypass.

The static switch shall use inverse parallel connected 600 volt silicon controlled rectifiers with an ampacity suitable to carry ten times the inverter's capacity for one cycle.

7.2 Operation

The static switch shall automatically connect the bypass source to the critical load and have the following features.

Uninterrupted Transfer - The static switch shall automatically transfer the critical load after the control logic senses one of the following conditions:

1. Inverter Failure
2. Inverter Over-current
4. Low DC Disconnect
5. Manual Transfer via front panel push button

Uninterrupted Automatic Retransfer - If the transfer control switch is set for automatic retransfer, the control circuit shall be capable of re-transferring the critical load to the inverter output when the overload is removed and the inverter output is within specification.

Uninterrupted Manual Retransfer - If the transfer control switch is set for manual retransfer, upon manual command the critical load shall be transferred to the inverter.

Transfer Lockout - The transfer logic shall not allow a transfer to the bypass source if one of the following conditions exist:

1. Bypass source out of sync with inverter output (Except for upon inverter failure or low DC disconnect.)
2. Bypass source not available

7.3 Transfer Time

The transfer time of the static switch shall be zero, resulting in an uninterrupted flow of power to the system loads.

7.4 Transfer Point

The static switch current sense transfer point shall be adjustable from 100% to 125%, factory set at 120%

The current sense shall be designed to prevent premature switching of the static switch with high crest factor loads.

7.5 Auto-retransfer Defeat

An internal switch shall be provided to defeat the automatic retransfer of the static switch after a transfer to the bypass source. Shipment setting for the unit shall be OFF (i.e. auto-retransfer not activated).

7.6 Overload Rating

The static transfer switch shall be rated for continuous operation at 125% of full rated load; 1000% for one (1) cycle.

8.0 MANUAL BYPASS SWITCH

8.1 General

A manually operated mechanical bypass switch shall be provided to facilitate system maintenance. In the bypass position, this switch and the static switch input breaker shall isolate the static switch from the bypass source and connect the output directly to the bypass power source.

8.2 Mounting

The manual bypass switch shall be mounted in the system enclosure to reduce interconnect wiring. (As an *option*, a remote mounted 3-position Manual bypass switch shall be available.)

8.3 Configuration

The manual bypass switch shall be of a "make-before-break" configuration to ensure absolute continuity of AC power to the critical U.P.S. loads during switch over.

The manual bypass switch shall not require the assistance of the static switch to insure a zero break load transfer.

8.4 Overload Rating

The manual bypass switch shall be rated for continuous operation at 125% of full rated load; 1000% for one (1) cycle.

9.0 ACCESSORIES

9.1 Controls

All controls specified below shall be accessible on the front panel unless otherwise noted.

9.1.1 Inverter to Load

A lighted momentary push button shall be provided to transfer the load to the inverter source.

9.1.2 Bypass to Load

A lighted momentary push button shall be provided to transfer the load to the bypass source.

9.1.3 Pre-Charge

DC filter capacitors on 20 KVA inverters and larger shall include a current limited pre-charge circuit, activated by pushbutton on the front panel of the inverter.

9.2 Meters

At a minimum the front panel shall be equipped with the following 3.5 inch scale analog meters (2% accuracy) for the following functions:

- Inverter Output Voltmeter w/switch
- AC Output Ammeter w/switch
- Inverter Output Frequency Meter (expanded scale)

9.2.1 Optional Meters

Other, *optional*, meters shall be available, to include:

- DC Input Voltmeter
- DC Input Ammeter
- System Output Voltmeter
- Bypass Source Input Voltmeter
- Bypass Frequency Meter
- Bypass Ammeter

9.3 Indicating Lights and Alarms

The system shall be equipped with long-life LED's. A form "C" contact (SPDT) rated 3 amps@120VAC/27VDC shall be furnished for each specified alarm.

9.3.1 Battery Supplying Load

An indicator (Red) and alarm contact shall be provided to indicate when the battery is supplying power to the load through the inverter (DC bus voltage <127 VDC; 255 VDC on nominal 250 VDC systems). The relay shall be normally energized.

9.3.2 Bypass Source Failure

An indicator (Red) and alarm contact shall be provided to indicate when the bypass source has failed. The relay shall be normally energized.

9.3.3 Inverter Supplying Load

An indicator (Amber) shall be provided to indicate when the load is being powered by the inverter.

9.3.4 Fan Failure

An indicator (Red) and alarm contact shall be provided when any fan has failed. The relay shall be normally de-energized.

9.3.5 Low DC Disconnect

An indicator (Red) shall be provided to indicate when the DC input breaker has tripped due to low DC disconnect caused by the battery reaching its end of discharge voltage level.

9.3.6 In Sync

An indicator (Green) shall be provided when the internal oscillator of the inverter is synchronized to a bypass reference source that is within +/- 0.5 Hz of 50 or 60Hz.

9.3.7 Static Switch Transfer

An alarm contact (no indicator light) shall be provided to sense when the inverter is supplying power to the load. The relay shall be normally energized.

9.3.7 Static Switch Position

Indicators (w/o alarm contacts) shall be supplied to indicate the position of the static switch.

9.3.8 Pre-Charge

An indicator for inverter pre-charge shall be supplied on inverter sizes 20 kVA and larger.

9.3.9 Inverter Failure

An indicator (Red) and alarm contact shall be provided to indicate when the inverter has failed. The relay shall be normally energized.

9.4 Optional Indicating Lights and Alarms

The following **Optional** Indicating lights shall be provided on the mimic panel, when required; total number not to exceed the physical limitations of the mimic panel.

9.4.1 High DC Voltage

An indicator (Red) and alarm shall be provided when the inverter DC input voltage is greater than 144 VDC. The relay shall be normally de-energized.

9.4.2 Low DC Voltage

An indicator (Red) and alarm shall be provided when the inverter DC input voltage is less than 120 VDC (240 VDC on nominal 250 VDC systems). The relay shall be normally de-energized.

9.4.3 High DC Disconnect

An indicator (Red) and alarm shall be provided when the DC Input Breaker has tripped due to High DC Disconnect (DC bus voltage > 145 VDC (290 VDC on nominal 250 VDC systems) for 5 seconds). The relay shall be normally de-energized.

9.4.4 Negative to Ground

An indicator (Red) and alarm shall be provided when the voltage between positive DC and ground exceeds 65% of nominal output voltage. This alarm is used in conjunction with the Positive DC Ground Detect as a voltage divider. The relay shall be normally de-energized.

9.4.5 Positive to Ground

An indicator (Red) and alarm shall be provided when the voltage between negative DC and ground exceeds 65% of nominal output voltage. This alarm is used in conjunction with the Negative DC Ground Detect as a voltage divider. The relay shall be normally de-energized.

9.4.6 Over-temperature

An indicator (Red) and alarm shall be provided when the ambient temperature is excessive (typically >65°C) . The relay shall be normally de-energized.

9.4.6 Bypass Source Low Voltage

An indicator (Red) and alarm shall be provided when the bypass source is less than 80% of nominal. The relay shall be normally energized.

9.4.7 Bypass Source High Voltage

An indicator (Red) and alarm shall be provided when the bypass source is greater than 19% of nominal. The relay shall be normally de-energized.

9.4.7 Low AC Output

An indicator (Red) and alarm shall be provided when the AC output voltage is less than 80% of nominal. The relay shall be normally energized.

9.4.8 High AC Output

An indicator (Red) and alarm shall be provided when the AC output voltage is greater than 19% of nominal. The relay shall be normally de-energized.

9.4.9 UPS Trouble (Summary)

An indicator (Red) shall be provided. The alarm status shall activate if any of the alarm conditions specified occur. The relay shall be normally energized.

9.4.11 UPS Trouble (Summary) with Audible Alarm

An indicator (Red), alarm, and audible alarm (front-mounted buzzer) with silence switch shall be provided. The alarm status shall activate if any of the alarm conditions specified occur. The relay shall be normally energized.

9.4.12 Out of Sync

An indicator (Red) and alarm shall be provided when the inverter's internal oscillator is not in synchronization with the bypass source. The relay shall be normally energized.

9.4.13 Inverter fuse Blown

An indicator (Red) and alarm shall be provided when the inverter fuse is blown. The relay shall be normally de-energized.

9.4.14 Static Switch Fuse Blown

An indicator (Red) and alarm shall be provided when the inverter input fuse to the static switch is blown. The relay shall be normally de-energized.

9.4.14 Push-To-Test Feature

A pushbutton shall be provided to test all LEDs.

9.4.15 Latching Alarm

A latching alarm with reset shall be provided to latch alarms that occur until the reset button is pressed.

9.4.16 Manual Bypass Switch Position Indicator

Two indicators and two SPDT alarm contacts shall be provided to indicate switch position: Normal and Bypass To Load. One alarm relay is energized and the other is de-energized under normal operation.

9.5 Overload Protection

The overload protection devices shall not be activated when the system is started under any normal operating conditions.

9.5.1 Bypass Circuit Breaker

A front access molded case breaker shall be provided for Bypass disconnection and overload protection. The A.I.C. rating of the breaker shall be 9KA minimum.

9.5.2 Inverter Input Circuit Breaker

A molded case breaker shall be provided for DC input disconnection of both input lines and overload protection. The A.I.C. rating of the breaker shall be 9KA minimum.

9.5.3 Semiconductor Fuses

The semiconductors shall be protected from cascaded failure with special fast acting fuses.

10.0 GENERAL REQUIREMENTS

10.1 Efficiency

The overall DC to AC efficiency shall be greater than 70% with the inverter at full rated load and nominal input voltage.

10.2 Audible Noise

The audible noise generated by the unit under rated operating conditions shall not exceed 70 - 78 dBA at a distance of 1.5 meter (typical) from any side of the enclosure and 3 feet above ground. The sound levels shall be measured with the unit operating at rated load, voltage and frequency. Note: addition of a drop/drip shield may increase audible noise by 1-3 dB.

10.3 Cooling

Forced-air cooling shall be provided when necessary to ensure that all components are operating at below their specified operating temperature.

10.4 Wiring

Manufacturer shall utilize NEC, bulletin 70 (US National Electric Code) and NEMA-PE-1 and PE-5 wiring practices where applicable.

Printed Circuit Board control wire shall be 18 AWG UL 3266 cross-linked Polyolefin (XLPE) 300 Volts, 105°C rated.

Control wire and Power wire shall be either SIS or XLPE, depending on the ampacity required.

Power wiring 10AWG through 4/0 AWG shall be SIS UL, CSA listed VW-1, 80°C, 600 V.

Power wiring 262 MCM through 777 MCM shall be DLO 80°C, 600 Volt Ethylene Propylene Rubber (EPR) inner jacket, with a Hypalon outer jacket.

All wiring and bus-work shall be copper throughout the system.

10.5 EMI Suppression

Electromagnetic effects shall be minimized to ensure that computer systems, or other similar electronic systems, shall neither adversely affect nor be adversely affected by the system.

10.6 Transformers

All power transformers or chokes shall be designed using copper windings for reliability and efficiency. The insulation type shall have a temperature rating of at least 200 C (UL 1446, Class N).

An epoxy based insulating varnish shall be applied with a V P I (Vacuum Pressure Impregnation) system to insure a low temperature rise over the 30-year design life of the transformer.

10.7 Nameplate Markings

The nameplate shall be located on the front inside display door and the following minimum information shall be provided on the nameplate:

- a. Solidstate Controls, Inc., Model # and Serial #
- b. Bypass AC Input Voltage, Phase and Frequency
- c. DC Input Voltage and Current
- d. Rated Output Voltage, Amps, Frequency, Power Factor, kVA and kW.

11.0 MECHANICAL SPECIFICATIONS

11.1 Enclosure

The enclosure shall be a NEMA-1(IP-20), free standing, with minimum 11GA framework. Door panels shall be a minimum of 14GA steel and side panels shall be a minimum of 17GA.

The enclosure shall be mounted on channels with a 3-inch lifting base open at the front and back to facilitate moving with a forklift and to provide an entrance area for air movement through the enclosure.

The enclosure shall be designed with blank plates on the sides and rear for installation against a wall. The equipment shall be designed to allow replacement or maintenance of all components from the front.

One or more hinged doors shall be provided in the front with door locks on each. Hinged panels, 36" and larger, shall be provided with a 2 point latching system for holding the panels securely. Removable covers shall be attached with machine screws.

11.1.1 Drop and Drip Shields

When required, “drop” shields, which protect the enclosure from debris and foreign objects falling into the cabinet; or “drip” shields which protect the enclosure by preventing dripping water from entering the cabinet from above, shall be provided on the top of the enclosure.

11.1.2 Fungus and Moisture Proofing

When specified, a protective coating on components inside the UPS enclosure shall be provided when the unit is installed in environments where the ambient air is extremely humid, or is heavily laden with salt content or other contaminants.

11.1.3 Vermin Screens

When specified, vermin screens shall be provided to prevent the entry of small animals into the inverter cabinets.

11.2 Ventilation

Air inlets and outlets shall be protected by screens or perforated metal guards to prevent the entrance of a rod having a diameter of 0.5 inches or longer.

11.3 Cable Entry

Cable entry shall be through the top or bottom of the cabinet.

11.4 Power Connections

The connections to the AC output or DC input shall be of the stud type and shall be sized for full load service.

Alarm connections shall be sized to allow connection of 11AWG Wire maximum. The alarm terminal boards shall be rated for 300 VAC.

11.5 Parts Placement

The system shall be designed to permit front access to modules, fuses, and assemblies. Parts, test points, and terminals shall be placed so they are accessible for circuit checking, adjustment, and maintenance without removal of any adjacent assembly or component or pose a shock hazard.

11.6 Wire Supports

Permanent wire supports shall be used; no adhesive backed wire supports shall be used.

11.7 Wire Marking

All point-to-point wires shall be marked with a permanent marking system on both ends of each wire.

11.8 Component Marking

All PCB's, indicator lights, meters, controls, semiconductors, and fuses shall be clearly marked with the component designation for ease of serviceability.

11.9 Personnel Safety

The cabinet shall be constructed so that all controls, except float/equalize, are operable with the doors closed, preventing exposure to high voltage terminals. High voltage warning labels shall be visible when any of the cabinet doors are opened.

11.10 Painted Surfaces

All external painted surfaces shall be ANSI 61 Gray enamel with a minimum of 2.0 mil thickness and shall be smooth with no runs, sags, or graininess. All internal mounting plates shall be painted white.

12.0 SHOP TESTING

The system testing shall be in conformance with IEEE 844-1876 section 7.0, and IEC-146-4. Certified test data shall be supplied to verify test results. The manufacturer shall have type-test data available to demonstrate system performance with switch-mode type power supplies.

13.0 DOCUMENTATION

13.1 Cabinet outline and interconnect drawings shall be dimensioned and scaled, and include the following information:

- 13.1.1 Location of any removable plates for Owner's conduit entry.
- 13.1.2 Location and size of all terminal blocks for Owner's connections.
- 13.1.3 Location and size of ventilation openings.
- 13.1.4 Location of cabinet grounds.
- 13.1.5 Block diagram including currents for customer cable sizing, breaker locations and sizes, and meter locations.
- 13.1.6 Size and weight of equipment.

13.1.7 Front panel identification chart.

13.1.8 Nominal heat loss for the specified equipment.

13.2 Schematic type drawings shall include the following information:

13.2.1 System schematics shall include item designations for all electrical components.

13.2.2 Relay contacts diagrams shall be shown in the de-energized position.

13.2.3 Wire sizes and numbers shall have the same designations that appear in the equipment.

14.0 PREPARATION FOR SHIPMENT

14.1 Preparation for shipment shall be in accordance with the manufacturer's standard shipping procedure.

14.2 One complete set of instruction books and "as-built" drawings shall be included with the equipment when shipped.

14.3 To facilitate site access, shipment of individual cabinets, rather than complete lineups, may be necessary.